

PRODUCT SUBMITTAL



WIRE-BOND

RJ-721 Test Results

ANCHOR TYPE :	RJ721
ANCHOR DESCRIPTION:	14 Gauge with 11 gauge adjustable seismic tie.
DATE TESTED:	03/18/09

ANCHOR NO.	MODE	LOAD AT FAILURE (LBS)	DEFLECTION AT 100 LBS. (INCHES)	AREA OF FAILURE
1	Tension, 1-1/4" disnegagement	379	0.072	Pulled out of slot of Anchor Pulled out of slot of Anchor Pulled out of slot of Anchor
2		438	0.068	
3		367	0.070	
Average		395	0.070	
4	Tension, 5/8" disnegagement	729	0.039	Broke Slot of Anchor Broke Slot of Anchor Broke Slot of Anchor
5		753	0.039	
6		756	0.040	
Average		746	0.039	
7	Tension, 0" disnegagement	713	0.033	Broke Slot of Anchor Broke Slot of Anchor Broke Slot of Anchor
8		691	0.031	
9		826	0.036	
Average		743	0.033	

Corporate Office: 400 Rountree Rd Charlotte, NC 28217
TEL: (800) 849-6722 FAX: (704) 525-3761

Mailing Address: P.O. Box 240988 Charlotte, NC 28224



Memphis Plant: 2365 Harbor Ave. Memphis, TN 38113
TEL: (800) 441-8359 FAX: (901) 775-9449

Mailing Address: P.O. Box 13124 Memphis, TN 38113